

Do NOT operate the UPS where the temperature and humidity is out of the specific limits. (Please check the specs for the limitations.)

Figure 3-2 Storage Conditions



3.2 Connect to Utility and Charging

Plug in the AC input power cord to the wall outlet. For the best results, it is suggested to charge the battery for at least 6 hours.

Before initial use, the UPS charges its battery while connecting to the utility.